

## **RFP for Family Site Electric Service Panel Replacement**

*BID ADDENDUM No. 2*

*September 15, 2020*

*To All Interest Bidders:*

***Correction, all circuit breakers will be standard breakers, they do not need to be ground fault or arc rated.***

***Materials. Because of available, the Housing Commission will allow venders to submit Voluntary Alternates for other manufacturer Service Panels from Siemens and Leviton as long as they meet equal specification as Square D Homeline. All panels must be 100 amp rated with a minimum of 30 breaker spaces.***

### **Voluntary Alternate Bids**

Bidders may submit voluntary alternate bids for equal or enhanced products or materials that produce savings for the owner. Any brochures, specification sheets, etc. must accompany each voluntary alternate. Any voluntary alternate submitted may be used to the benefit of the owner even though the bidder submitting the alternate may not be awarded the contract. ***Write or type your Voluntary Alternate deduction or addition cost on the bid sheet under the base bid cost line.***

Assistant Director Karl Opheim spoke with Bay City Electrical Inspector Peter Zurch and he will do his best to work with the contractor for additional availability for final inspections on his non-Bay City days (Monday, Wednesday, Friday). He encourages two inspections on Tuesdays and Thursdays. Specific inspection arrangements will need to be made with Mr. Zurch. I mentioned BCHC objective is to try and complete this project in approximately 10 weeks.

**END OF THIS ADDENDUM**